



CONCRETE SIDEWALK AND GRANITE CURB
SCALE 1":2'

NOTES:

1. ALL ITEMS ARE TO BE COVERED BY AND IN CONFORMITY WITH NYSDOT STANDARD SPECIFICATIONS UNLESS OTHERWISE NOTED.
2. CONCRETE FOR SIDEWALKS AND DRIVEWAYS SHALL MEET AT LEAST 4000 PSI COMPRESSIVE STRENGTH AT 28 DAYS.
3. SIDEWALK TO BE PICTURE FRAME AND BROOM FINISHED. A FUGITIVE DYE CURING AND SEALING COMPOUND MEETING NYSDOT STANDARD SPECIFICATIONS 711-05 & 717-04 SHALL BE APPLIED WITHIN 30 MINUTES OF CONCRETE FINISHING. COST TO BE INCLUDED IN PRICE BID FOR ITEM 608.010100TO OF THE SPECIAL SPECIFICATIONS.
4. EXPANSION JOINT TO BE INSTALLED EVERY 25 LF OF SIDEWALK. COST OF EXPANSION JOINT MATERIAL IS INCIDENTAL TO ITEMS SHOWN.
5. 6" CURB REVEAL REQUIRED UNLESS OTHERWISE DIRECTED BY THE ENGINEER.
6. GRANITE CURB SHALL BE BACKED UP WITH A CONTINUOUS CONCRETE ALONG THE BACK SIDE OF THE CURB. CONTRACTOR SHALL USE ANY CLASS OF NYSDOT CONCRETE MEETING THE REQUIREMENTS OF 501-3 STANDARD SPECIFICATIONS.
7. GRANITE CURB SHALL BE BUTTED TOGETHER WITH NO MORTAR BETWEEN JOINTS.
8. DILUTED TACK COAT. ITEM 407.0102, SHALL BE USED BETWEEN ALL LIFTS OF PAVEMENT.



CITY OF ITHACA
108 E. GREEN ST.
ITHACA, NY 14850

PROJECT NAME			
SIDEWALK IMPROVEMENT DISTRICT			
SHEET NAME			
CONCRETE SIDEWALK AND GRANITE CURB CONSTRUCTION STANDARD DETAIL			
DESIGN BY:	AR	APPROVED BY:	JL
DRAWING NO. XS-02	DATE:	JAN-2020	
CHECKED BY:	JL	PROJECT NO. _____	SCALE: AS SHOWN
SHEET:	1 OF 2		